

IQAir®

Certificate of Performance

IQAir Model:

HealthPro

Article No.:

1 0 1 2 4 6 0 6 0

Testing carried out by:

Signed:



Testing & QC Dept.

Test Voltage/Frequency:

115 V / 60 Hz

Serial No.:

0 0 3 6 9 7 6 8 5

This certifies that the aforementioned air cleaning device has been tested prior to packaging at the IQAir production facility in Switzerland. This particular device has been found to be in compliance with the model's published specifications for air delivery and particle filtration efficiency. This particular device has passed the particle leakage test.

I. Air Delivery Rate

The aforementioned device has been tested for its air delivery at all fan speed settings. Due to component tolerances, a divergence of 5% + 6 cfm is deemed acceptable.

Note:

The air delivery rate refers to the unit's initial air delivery, which will decrease as filters load up with dust particles.

Published Air Delivery

Speed 1: 35 cfm

Speed 2: 60 cfm

Speed 3: 85 cfm

Speed 4: 115 cfm

Speed 5: 150 cfm

Speed 6: 240 cfm

Actual Air Delivery

Speed 1: 34 cfm

Speed 2: 61 cfm

Speed 3: 87 cfm

Speed 4: 114 cfm

Speed 5: 148 cfm

Speed 6: 241 cfm

Measuring instrument: Alnor LoFlo Balometer.
Instrument accuracy: ± (3% + 2 cfm).

cfm = cubic feet per minute